

## TRANSFORMER SERIES 2-2.4 VA



Transformer 50/60 Hz , approval UL KEMA ENEC 05  
 According to EN 61558-2-6 UL506  
 Approval KEMA on primary voltage 230 V n. licence 3502486.01  
 Approval UL (also CSA Canada) on voltages 120 and 230 V n. file E216737  
 Approval also with asymmetric secondary voltages  
 Two chamber winding  
 Class II IP00  
 Insulation class Ta 70°B  
 Short-circuit proof  
 Potted under vacuum  
 For according to the standard no series up 2x18 V



Standard voltages list (for complete the code insert secondary voltage wanted)

CODE	PRIMARY	POWER	PIN	SECONDARY	PIN
120--2	120 V	2 VA	1-5	6...24 V	7-9
230--2	230 V	2 VA	1-5	6...24 V	7-9
120---2	120 V	2 VA	1-5	2X6...2X24 V	6-7 9-10
230---2	230 V	2 VA	1-5	2X6...2X24 V	6-7 9-10
120--2.4	120 V	2.4 VA	1-5	6...24 V	7-9
230--2.4	230 V	2.4 VA	1-5	6...24 V	7-9
120---2.4	120 V	2.4 VA	1-5	2X6...2X24 V	6-7 9-10
230---2.4	230 V	2.4 VA	1-5	2X6...2X24 V	6-7 9-10

